

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:59 am

**PWS ID:** UTAH09086      **Name:** OFFSHORE MARINA  
**Legal Contact:** OFFSHORE MARINA  
HAROLD LLOYD BERTOLA  
**Address:** HCR 60 BOX 330330  
LAKE POWELL, UT 84533  
**Phone Number:** 435-788-2142  
**City Served (Area):**  
**County:** GARFIELD COUNTY  
**System Type:** Non-community  
**Activity Status Cd:** Active  
**Population:** 25  
**Rating:** Approved  
**Rating Date:** 09/18/2003  
**Activity Status:** Active  
**Last Inv Update:** 12/28/2010  
**Last Snty Srv Dt:** 12/16/2009  
**Surveyor:** JOHN GALLIS  
**Oper Period:** 1/1 to 12/31

**Gal/Day**    **Gal/Min**

**Avg Daily Prod:**

**Total Dsgn Cap:**

**Total Emerg Cap:**

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	BERTOLA, HAROLD LLOYD		435-788-2142	801-943-2520	mrb8290@hotmail.com

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	2
			2 Total Svc Connections

### Storage

**Total Storage:** 13,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	MACKAY STORAGE TANK	Reservoir	8,000			A	
ST001	SOUTH STORAGE TANK	Reservoir	5,000			A	

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NORTH WELL #2	Inactive	WL				Yes	GW	Permanent		
WS002	MACKAY WELL #1	Active	WL			105 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.